

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 72

Dated: 25-4-2025

It is certified that an inspection team headed by Dr. Sandeep Rajput

(Name of Officers with designation) from Medical officer, CHC Nuh

(Name of Department/ Office) inspected the Maria Manzil School, Nuh

(Name & Address of the school) on 25-04-2025 (date of inspection) and found that the
 Maria Manzil School, Nuh (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 2025-2026.

Signature with Seal: 25/4/25

Name

: Dr. Sandeep Rajput

Designation

: Medical officer


Name & Address of the Officer in Charge
C.H.C. Nuh-Mewat

To MARIA MANZIL SCHOOL
 TAURU ROAD NEAR

BHARAT PETROL PUMP PALLA NUH

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate
 as a single pdf.



Principal
 Maria Manzil School
 Tauru Road, Near Bharat
 Petrol Pump, Nuh
 Haryana 122107

Memo No:- 375

Date:- 08/05/2025

Certificate
No: TC-11870

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	MEW/00700/5/2025 / Private	Sample Details	Date & Time
Sender :	MARIA MANZIL SCHOOL	Collected By	TAHIR HUSSAIN
Location :	, TAURU ROAD, NEAR BHARAT PETROL PUMP, NUH	Collection Date	06/05/2025 at 09:31
Sample Description :	Drinking Water	Received at lab	06/05/2025 at 11:20
Latitude / Longitude :	76.998324 / 28.115670	Analysis Start Date	06/05/2025
		Analysis End Date	06/05/2025
		Sample Quantity	1 Liter

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<0.5	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2022)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
4	Color	<5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	162	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	88	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	18	75 mg/lit.	200 mg/lit.	APHA 24th Edition -3500 Ca B
8	Magnesium as Mg	11	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg-B
9	Total Alkalinity	129	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	55	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	44	200 mg/lit.	400 mg/lit.	APHA 24th Edition -4500 SO4-E
12	Fluoride as F	<0.1	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition -4500 F-D
13	Iron as Fe	<0.1	1.0 mg/lit.	1.0 mg/lit.	APHA 24rd Edition -3500 Fe-B
14	Nitrate as No3	4.9	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3-D
15	pH @ 25°C	7.79	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition -4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED MEWAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

TAHIR HUSSAIN, CHEMIST
DISTRICT WATER TESTING LABORATORY MEWAT
email-chemist.mewat@phedharyana.gov.in

(Signature)
Principal
Maria Manzil School
Tauru Road, Near Bharat
Petrol Pump, Nuh
Haryana-122107